

# TYPE APPROVAL CERTIFICATE

Certificate no.: TAE000038S Revision No: 1

This is to certify: that the Low Voltage Cable

with type designation(s) **FM2XAAH-FFR** 

issued to Untel Kablolari San. ve Tic. A.S. Dilovası, Türkiye

is found to comply with DNV rules for classification – Ships, offshore units, and high speed and light craft

## **Application:**

Control and instrumentation cables. Products approved by this certificate are accepted for installation on all vessels classed by DNV.

Rated voltage (V)150/250Temp. class (°C)90

Issued at Høvik on 2024-08-16

This Certificate is valid until **2029-01-16**. DNV local unit: **Istanbul** 

Approval Engineer: Ivar Bull

for **DNV** 

.....

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



 Job ID:
 262.1-028904-2

 Certificate no.:
 TAE000038S

 Revision No:
 1

## **Product description**

Type:

FM2XAAH-FFR

Halogen free, XLPE insulated and thermoplastic sheathed shipboard communication and signal cable

••	
Rated voltage:	150 / 250 V
Maximum operating conductor temperature:	90° C
Conductor:	Stranded copper conductor, class 2 / 5 (tinned optional)
Insulation:	Mica tape + XLPE
Individual screen:	Aluminum tape+ drain wire
Overall screen:	Aluminum tape+ drain wire
Outer sheath:	Thermoplastic polyolefin based compound / SHF1

No of Pairs:	Cross sectional area [mm <sup>2</sup> ]	
2 to 7	0,75	

## Application/Limitation

This type of cable is fire resistant in accordance with IEC Publication 60331.

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

## Type Approval documentation

Test report :	Üntel Kablolari dated 23.01.2013	
	TÜV Rheinland No. 15058916001, dated 29.03.2013	
	TSE 173516 -01/13, dated 28/01/2013	
Data sheets:	Manufacturer's specifications	

### Tests carried out

Standard	Release	General description	Limitation
DNV CP-0399	2021-08	Electric cables.	
IEC 60092-350	2020-01	Electrical installations in ships - Part 350: General construction and test methods of power, control and instrumentation cables for shipboard and offshore applications	
IEC 60092-360	2021-01	Electrical installations in ships - Part 360: Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation and telecommunication cables	
IEC 60092-376	2017-05	Cables for control and instrumentation circuits 150/250 V (300 V)	
IEC 60331-1	2018-03	Fire resistance / Circuit integrity – Test for method for fire with shock at temperature of at least 830°C for cables rated up to and including 0,6/1 kV	For cables with an overall diameter exceeding 20 mm
IEC 60331-21	1999-04	Tests for electric cables under fire conditions Circuit integrity Part 21: Procedures and requirements. Cables of rated voltage up to and including 0,6/1,0 kV	For cables with an overall diameter not exceeding 20 mm
IEC 60332-3-22	2018-07	Tests on electric and optical fibre cables under fire conditions - Part 3-22: Test for vertical flame spread of vertically mounted bunched wires or cables - Category A	Charred portion of sample does not exceed 2,5m above bottom edge of burner.
IEC 60754-1	2019-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	Low Halogen: <0,5% Halogen
IEC 60754-2	2019-11	Test on gases evolved during combustion of materials from cables - Part 2: Determination of acidity (by pH measurement) and conductivity	Halogen free: pH > 4,3 Conductivity < 10µS/mm



Standard	Release	General description	Limitation
IEC 61034-1/2	2019-11	Measurement of smoke density of cables burning under defined conditions – Part 1: Test apparatus Part 2: Test procedure and requirements	Low smoke Light transmittance >60%

## Marking of product

ÜNTEL – FM2XAAH-FFR – size – 250 V - IEC 60332-3-22– IEC 60331-1/21

#### **Periodical assessment**

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine Tests (RT) checked (if not available tests according to RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE